

Government Of West Bengal Office Of The Director General West Bengal Fire & Emergency Services 13D, Mirza Ghalib Street, Kolkata - 16

Memo no::FSR/0125186221200035

Date: 13-04-2023

From:

Director

Fire Prevention Wing.

West Bengal Fire & Emergency Services

To: Biswanath Institute of B.Ed College Plot no. 665,702,704,705,701/1243 Mouza- Mojlispur , JL no.- 77, Vill.-Mojlispur, P.O.-Pairachali, Falta Road, South 24 Parganas, Pin-743503.

Sub: Fire Safety Certificate for the occupancy of an existing G+II storied building under group of Educational Building in the name & Style of "BISWANATH INSTITUTE OF B.ED COLLEGE", a Unit of Mahila Sebayatan, at the Plot no - 665,702,704,705,701/1243 Mouza - Mojlispur, JL no - 77, Vill- Mojlispur, P.O - Pairachali, Falta Road, south 24 parganas, Pin - 743503...

This is in reference to your application no. 0125189231200047 dated 08-03-2023 regarding the. Fire Safety Certificate for the occupancy of an existing G+II storied building under group of Educational Building in the name & Style of "BISWANATH INSTITUTE OF B.ED COLLEGE", a Unit of Mahila Sebayatan, at the Plot no - 665,702,704,705,701/1243 Mouza - Mojlispur, JL no - 77, Vill- Mojlispur, P.O - Pairachali, Falta Road, south 24 parganas, Pin - 743503.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building

Recommendation:

- 1) Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on
- 2) Entrance/Exits as marked in the sanctioned plan drawing must be open & free from any type of obstruction.
- 3) The Interior finish decoration of the building shall be made with low flame spread material confirming to the LS.
- 4) To eliminate risk of Fire Hazards, Good House Keeping both for inside and outside of the building shall be strictly maintained.
- 5) Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them. If required the old electrical lines shall be replaced with new electrical lines, cables shall always be laid in M.S. conduit pipes continuously bonded to the earth
- 6) All fire pumps, alarm which are incorporated in the building kept in auto mode round the clock.

The authoritions of this document can be verified by accessing the URL edistrict wit gov in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Urique Number - 0125189231200047. Page 1

- 7) The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
- 8) The employee and security staff shall be conversant with installed Firefighting equipment of the building and to operate in the event of Fire and Testing.
- Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 10) Switch gear room, Main & meter area shall be protected with Co2/DCP Fire Extinction conforming I.S. Specification
- 11) First-Aid Firefighting system shall be provided as per I.S. Specifications.
- 12) Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them to perfectly good working condition at all times.
- 13) Periodical flashing of water from the hydrant and hose reel hose shall be done to maintain the efficient working performance of the system.
- 14) All floors of electrical ducts shall have to sealed as per norms.
- 15) Electrical main & meter room to be maintained all time proper safety measures.
- 16) Fire Safety Audit shall be conducted a regular interval and to be recorded in the Fire Prevention Maintenance Register
- 17) Emergency lighting system to be installed in the stair case for the safe evacuation.
- 18) A fire control room including a close circuit T.V. system will have to be installed which will observe all the floors of the building.

This Fire Safety Certificate is valid for Three years and has to be renewed before expiry of the date of issue of this letter

Every three year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all life & Fire Safety arrangements and installation of the building.

Signature valid Digitally signed a ABHUIT PANDEY DAW 2023 0W 3 15-50-33 IST

Director
West Bengal Fire & Emergency Services